

INTER-TECH

B-33 Flatted Factory Complex,
Near Modi Mills
Okhla New Delhi - 110 020

Telephone 011 26312127, 9313710964
Fax: 011 26832127
E Mails: kkgupta@intertech.com.co

Earth Resistance Measurement Report

Report no: IT/144

Date: 22nd Dec 2012

Date of Measurement : 22/12/2012

Organization : Indraprastha Apollo Hospitals, Sarita Vihar, New Delhi - 76

Site Location : On road above DG sets area.

Under Supervision : Sh. Gursharan Singh, Engineer Service, Ind. Apollo Hospital

IT Represented by : Sh. Manmohan Singh & Sh. Amarjeet Singh

Method of Measurement : E D Curd's method.

Standards Applicable : Section 36.4 of IS 3043/1987

Instrument Used : Digital Earth Tester

Make : MEGGER


Model : DET4TD2

Sr. No : 101139510

Earth Resistance Measurement reading : 0.51 Ω

Next Measurement Due on : On 22nd Jan 2013.

Measurement Witnessed by



(Gursharan Singh)
Engineer Service
Indraprastha Apollo Hospitals, New Delhi

Measurement Carried out by



(Manmohan Singh)
Testing Engineer
Inter - Tech, New Delhi