

INTER-TECH

B-83 Flatted Factory Complex,
Near Modi Mills
Okhla New Delhi - 110 020

Telephone 011 26312127
Fax: 011 26832127
E Mails: info@intertech.com.co

Earth Resistance Measurement Report

Report no: IT/148

Date: 23/09/2013

Date of Measurement : 23/09/2013

Specifications of Earth Electrode : Marconite Embedded Earth Electrodes.
Two numbers - Size: Dia 100 mm, Length 15 m with 16 mm Dia Cu Conductor.

Organization : M/s Bhushan Steel Limited, 23, site IV Sahibabad Indl. Area,
Sahibabad Dist. Ghaziabad - 201010 UP

Site Location : Main administrative Building - for IT application

Under Supervision : Sh. Rajeev Gupta E/M Department

IT Represented by : Sh. Amarjeet Singh

Method of Measurement : Fall of Potential method.

Standard : Section 36 of IS 3043/1987

Instrument Used : Megger Earth Tester Make : MEGGER

Model : DET4TD2 Sr. No. : 101139510

Calibration Validity : Upto 23/04/2014

Readings : Earth Resistance Measurements: -

Both the electrodes installed in parallel and shorted 0.33Ω

Measurement carried by:


(Amarjeet Singh)
Inter - Tech

Measurement witnessed by:


(IT Department)


(E/M Department)

Bhushan Steel Limited