



दिल्ली मेट्रो रेल कॉर्पोरेशन लि० DELHI METRO RAIL CORPORATION LTD.

(भारत सरकार एवं दिल्ली सरकार का संयुक्त उपक्रम)

(A JOINT VENTURE OF GOVERNMENT OF INDIA AND GOVT. OF DELHI)

DMRC/O&M/L-8/2025

Date:12.11.2025

To,

INTER-TECH

B-83 Flatted factory complex

Near Modi Mill Okhla Indl. Estate Phase-III

New Delhi-110020

Mob: 8377013775

Email:tarsem@intertech.com.co

(Performance certificate)

Sub: Performance of conductive Concrete Marconite Earthing at Jasola stabling line under CE 05 Lot-1.

Ref: Request letter for issue of performance certificate dated 05.08.2025

With reference to the above subject, it is certified that a total of 21 nos. of Conductive Concrete Marconite Earthing pits were installed by M/s Intertech at Jasola Stabling Line under Contract CE-05 Lot-1.

A joint inspection was carried out on 02.08.2025 by M/s Intertech, during which the earthing resistance values of the earthing pits were measured and found to be less than 1.0 ohm, which is within the acceptable standard.

S.No	Description	Status
1	Location	Jasola Vihar Saheen Bagh Stabling Line
2	Total Quantity	21
3	Year Of installation	2019
4	Performance	Satisfactory

On this basis, it is hereby certified that the till date earthing system has been functioning satisfactorily.

For information please

Yours Truly

Nabila Mariyam

Sr. DGM / E&M

Delhi Metro Rail Corporation Ltd.
Shivaji Stadium Metro Station
Connought Place, New Delhi-110001

(मेट्रो भवन, फायर ब्रिगेड लेन, बाराखम्बा रोड़, नई दिल्ली-110001)

Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001